



SECTION 51
 PLOT PLAN
 50' x 1" SCALE



BLDG No 5A



SHIPPING PLATFORM

GROUND FLOOR SPR'S 17A

LINE NUMBER	NUMBER OF LINES	TOTAL LINES	MAIN LETTER	NUMBER OF PIECES
#1	1	2	A	16
#2	1	1	B	10
3 to 8	1	6	C	2
9	1	5	D	3
10	1	1	E	3
11	1	4	F	4
12-13	1	2	G	4
14	1	21	H	4
15-17	1	3	I	4
18	1	1	J	4
19	1	5	K	4
20-21	1	2	L	4
22	1	5	M	4
23	1	8	N	4
24	1	1	O	4
			P	5
			Q	5
			R	4
			S	4
			T	4
			U	4
			V	4
			W	4
			X	6

SPRINKLERS					
165"	135"	212"	178"	386"	TOTAL
164	15				179

MARK PIPING FOR THIS STORY **NO PRINT**

NOTE - ALL PIPE MEASUREMENTS SHOWN ARE CUTTING DIMENSIONS. ADD 1/2 INCHES TO MEASUREMENTS SHOWN TO OBTAIN THE DISTANCE BETWEEN SPRINKLERS ON LINES.

J. L. PRICE & CO. LTD.
 MONTREAL P.Q.


BLDG **B.S.A. VICTOR COLTD.**
 MONTREAL P.Q.

SECTION **48** WAREHOUSE STORY **1ST.**

SCALE	CONT. NO.	DRAWING NO.	TUBE
1/8" = 1'	218521	11	
ENGINEER	DRAWN BY	DATE	CHECKED BY
M.S.L.	M.S.L.	4/4/40	
REVISED BY			

GRINNELL COMPANY
 OF CANADA, LTD.
 INSTALLATION DIVISION
 TORONTO, ONTARIO



1) Hooks for lines under just a semi mill construction.
 2) rings 1/2" rods a 1/2" hanger pipes for main (M.H. Roof)
 3) " " " 1/2" hanger pipes for lines & mains (concrete)
 (X) indicates ceiling to center of pipe.
 (M.T.) MACHINE THREAD ADD



LACASSE ST

— PLOT PLAN
50'-1" SCALE

(Notes: No. A-3 under plot form)
Freight Elevator No. 3
(Calcium chloride system)
3/4\"/>



SHIPPING PLATFORM

GROUND FLOOR 1005-111

LINE NUMBER	NUMBER OF LINES	TOTAL LINES	TYPE	NUMBER OF SPINKERS
1	1	1	F	1
2	1	1	A	1
3-8	1	1	F	2
9	1	1	F	3
10	1	1	F	3
11	1	1	F	4
12-13	1	2	F	4
14	1	31	H	4
15-17	1	3	H	4
18	1	1	H	4
19	1	5	H	4
20-21	1	2	H	4
22	1	5	H	4
23	1	6	H	4
24	1	1	H	5
			H	5
			F	4
			H	4
			H	4
			H	4
			H	4
			H	4


SPRINKLERS					
0	1	2	3	4	TOTAL
105"	195"	212"	175"	236"	807"
156		18			174

NOTE: ALL PIPE MEASUREMENTS SHOWN ARE CUTTING DIMENSIONS. ADD 1/4" INCHES TO MEASUREMENTS SHOWN TO OBTAIN THE DISTANCE BETWEEN EQUIVALENTS OF LINES.

J.S.E. PRICE & CO. LTD
MONTREAL, P.Q.

SECTION				STORY			
NEW				1ST			
SCALE	CONT. NO.	DRAWING NO.	TITLE				
1/4"=1'-0"	117-137	1					
ENGINEER	DRAWN BY	DATE	CHECKED BY				
M.S.E.	M.S.E.	4/14/40					
REVISED BY							

Indicates ceiling to center of pipe.
M.T.




LACASSE ST

PLOT PLAN
50'-1" SCALE


NEW - 6" SUPPLY P.I.
INSTALLED

DRIVEWAY

PIPE No. 5A



SHIPPING PLATFORM



GROUND FLOOR STORY III

LINE NUMBER	NUMBER OF LINES	TOTAL LINES	MAIN LETTER	DIAMETER OF BRACKET
11	1	1	H	1/2"
12	1	1	H	1/2"
13	1	1	H	1/2"
14	1	1	F	3/4"
15	1	1	F	3/4"
16	1	1	H	1/2"
17	1	1	H	1/2"
18	1	1	H	1/2"
19	1	1	H	1/2"
20-21	1	1	H	1/2"
22	1	1	H	1/2"
23	1	1	H	1/2"
24	1	1	H	1/2"
25	1	1	H	1/2"
26	1	1	H	1/2"
27	1	1	H	1/2"
28	1	1	H	1/2"
29	1	1	H	1/2"
30	1	1	H	1/2"
31	1	1	H	1/2"
32	1	1	H	1/2"
33	1	1	H	1/2"
34	1	1	H	1/2"
35	1	1	H	1/2"
36	1	1	H	1/2"
37	1	1	H	1/2"
38	1	1	H	1/2"
39	1	1	H	1/2"
40	1	1	H	1/2"

SPRINKLERS

Ø	150"	150"	210"	175"	230"	230"	230"	TOTAL
170	11							11

MARK PIPING FOR THIS STORY NO PIPING

NOTE - ALL PIPE MEASUREMENTS SHOWN ARE CUTTING DIMENSIONS. ADD 1/2 INCHES TO MEASUREMENTS SHOWN TO OBTAIN THE DISTANCE BETWEEN SPRINKLER OR VALVE.

J. J. C. PRICE & CO. LTD.
MONTREAL, P.Q.

BLDG. No. 5A
MONTREAL, P.Q.


SECTION No. 5A
STORY III

SCALE	CONT. NO.	DRAWING NO.	TUBE
1/4" = 1'-0"	5A-251	1	
ENGINEER	DRAWN BY	DATE	CHECKED BY
J.J.C.P.	H.S.	1/1/60	
REVISED BY			

Rec'd July 2/60

All work for this under steel & some mill construction. Advise rough 14" x 14" x 1/2" hanger pipes for wires (Mill Prof.) in 14" x 14" x 1/2" concrete.

(a) Indicates cutting to center of pipe.



LACASSE ST.

PLAT PLAN
50'-1" SCALE


NEW - C SUPPLY S.I.
INSTALLED

DRIVEWAY

Drive No. 57



SHIPPING PLATFORM



(Note: N. A. S. under plot form)
Screened in
Freight Elevator N. S.
(Calcium chloride system)

GROUND FLOOR 2ND 171

LINE NUMBER	NUMBER OF LINES	TOTAL LINES	MAIN LETTER	NUMBER OF PIECES
1	1	2	A	11
2	1	1	B	10
3-6	1	6	C	2
7	1	5	D	3
10	1	1	E	3
11	1	4	F	4
12-13	1	2	G	4
14	1	21	H	4
15-17	1	3	I	4
18	1	1	J	4
19	1	5	K	4
20-21	1	2	L	4
22	1	5	M	4
23	1	8	N	4
24	1	1	O	4
			P	5
			Q	4
			R	4
			S	4
			T	4
			U	4
			V	4
			W	4
			X	4

SPRINKLERS						
180°	195°	210°	195°	225°	240°	TOTAL
154		15				171

MARK PIPING FOR THIS STORY NO. PAINT
NOTE: ALL PIPE MEASUREMENTS SHOWN ARE CUTTING DIMENSIONS. ADD 1/2 INCHES TO MEASUREMENTS SHOWN TO OBTAIN THE DISTANCE BETWEEN SPRINKLERS ON LINES.

J. L. E. PRICK & CO. LTD.
MONTREAL P. Q.

BLDG
R.C.M. VICTOR CO. LTD.
MONTREAL P. Q.

SECTION
N.W.S. 1ST

SCALE
CONT. NO.
DRAWING NO.
TUBE

ENGINEER
DRAWN BY
DATE
CHECKED BY

REVIEWED BY

GRINNELL COMPANY
OF CANADA, LTD.
INSTALLATION DIVISION
TORONTO, ONTARIO

If books for lines under dust & semi well construction.
1/2" range 12 F. rods & 1/2" hanger pipes for wires (M.I. Roof)
" " " 1/2" hanger pipes for these wires (Gusset)

#18